

DISCLAIMER: The Block Design Collective (“BDC”) does not make any representations or warranties with respect to the accuracy or suitability of this information, and persons making use of this information do so at their own risk. BDC disclaims liability for damages of any kind, including any special, indirect, or consequential damages, which may result from use of this information. This information is not to be interpreted as indicating compliance with, or waiver of, any applicable building code, ordinance, standard or law.

DESIGNER NOTES:

CODE REQUIREMENTS

1.

TMS 402 REQUIRES THE ARCHITECT/ENGINEER TO INDICATE THE TYPE AND LOCATION OF MOVEMENT JOINTS ON THE PROJECT DRAWINGS. BDC RECOMMENDS THAT JOINTS ARE SHOWN GRAPHICALLY IN THE PLANS OR ELEVATIONS.
2.

REFER TO CMHA CMU-TEC-009-25 FOR MORE INFORMATION.

FIRE-RESISTANCE RATINGS

1.

CONTROL JOINTS THAT USE CERAMIC FIBER FELT (ALUMINA-SILICA FIBER) BETWEEN JAMB UNITS CAN ACHIEVE A 4-HOUR FIRE-RESISTANCE RATING. REFER TO CMHA CMU-TEC-009-25 FOR MORE INFORMATION.

VENEER

1.

IF USED FOR CAVITY WALL CONSTRUCTION, STANDARD "HOOK AND EYE" WIRE IS PREFERRED FOR ANCHORING THE VENEER TO THE CMU BACKUP WHERE PINTLES ARE INSERTED INTO THE EYELETS SHOWN.

